

# Attestation

## LEED v4 and v4.1 BETA

On the 9<sup>th</sup> of December 2022 for VOC emission and 17<sup>th</sup> of July 2023 for VOC content, Eurofins Product Testing A/S received a sample of a chemical anchor with the product name:

**HIT-CT 100**

supplied by

**Hilti Entwicklungsgesellschaft mbH**

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, EN 16516, CDPH 01350, and ASTM D2369 testing standards (See test report no. 392-2022-00544102\_H\_EN and no. 392-2023-20336501\_XG\_EN).

**The test results of the tested sample indicate that the product qualifies for LEED v4 and LEED v4.1 BETA (February 2021) projects globally by showing compliance with the specifications for VOC emissions and VOC content by complying with:**

**VOC emissions specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects globally:**

- The requirements of LEED v4 and LEED v4.1 BETA (February 2021): CDPH-IAQ (California Department of Public Health (CDPH) Standard Method v1.2-2017); and a TVOC below 0.5 mg/m<sup>3</sup> in both office and class room.

**VOC content specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects globally:**

- The requirements of LEED v4 and LEED v4.1 BETA (February 2021): South Coast Air Quality Management District (SCAQMD) Rule 1168 (2017) for "Multi-Purpose Construction Adhesives" having a VOC content below 70 g/L.

27 October 2023

  
Laura Hartung Sørensen  
Analytical Service Manager

  
Janne Rothmann Norup  
Analytical Service Manager

*LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.*